

Updated change list for Kifaru V2_R2 revisions:

Change List for Revisions

1. Installation of Extraction Fans

- **Description:** Install extraction fans to enhance thermal management within the facility.
- **Reason:** Improve airflow and temperature control.

2. Filter Design Upgrade

- **Description:** Upgrade filter design to G2 specifications with a width of 75mm.
- **Reason:** Enhance filtration efficiency and meet updated standards.

3. Updated Shelf Design

- **Description:** Revise shelf design to incorporate networking routing.
- **Reason:** Facilitate better organization and management of networking cables.

4. Roof Replacement

- **Description:** Replace the existing iron sheet roof with a tarp to enable better deployment of shading solutions.
- **Reason:** Improve flexibility and effectiveness of shading options.